

Number	KIP-07618	Replaces	KIP-15964/G Rev.1
Issue date	30-05-2024	Contract number	-
Due date	29-05-2034	Scope	(EU) 2016/426 (9 March 2016)
Report number	2002311/2	Module	B (Type testing)
PIN	0476CT2311		

EU TYPE-EXAMINATION CERTIFICATE (GAR)

Kiwa Cermet Italia declares that the central heating condensing boiler, type(s):

VICTRIX OMNIA
VICTRIX OMNIA 25

Manufacturer

IMMERGAS EUROPE S.r.o.
Priemyselna Ulica 4789
SK-05951 Poprad Metejevce, Slovakia

Meet the essential requirements as described in the
Regulation (EU) 2016/426 relating to appliances burning gaseous fuels.

Reference standard:
EN 15502-1:2021+AC:2022
EN 15502-2-1:2022

This certificate is only valid in combination with the appendix to this certificate, where specific information and/or conditions are given.

CERTIFICATE

Kiwa Cermet Italia S.p.A.
Società con socio unico, soggetta
all'attività di direzione e coordinamento
di Kiwa Italia Holding Srl

Via Cadriano, 23
40057 Granarolo dell'Emilia (BO)

Unità locale
Via Treviso 32/34
31020 San Vendemiano (TV)
Tel +39. 0438 411755
Fax +39.0438 22428
E-mail: info@kiwacermet.it
www.kiwa.it

Organismo Notificato n. 0476
Notified Body nr. 0476

Industry Division Manager
Maurizio Lorenzon

Digitally signed by: LORENZON
MAURIZIO
Date: 30/05/2024 15:54:55



PRD N° 0069PRD

Membro degli Accordi di Mutuo Riconoscimento EA, IAF e ILAC
Signatory of EA, IAF and ILAC Mutual Recognition Agreements

Number KIP-07618 **Page** 1 of 1
Issue date 30-05-2024 **Scope** (EU) 2016/426 (9 March 2016)
Due date 29-05-2034 **Module** B (Type testing)
Report number 2002311/2
PIN 0476CT2311

APPENDIX TO EU TYPE-EXAMINATION CERTIFICATE (GAR)

Brand name:
IMMERGAS

Types:

Model name	Heat Input (Hi)	
	CH Max – Min (kW)	DHW Max – Min (kW)
VICTRIX OMNIA	20,8 – 4,2	25,7 – 4,2
VICTRIX OMNIA 25	20,8 – 4,2	25,7 – 4,2

Appliance types:

B23, B23P, B53, B53P, C13, C33, C43, C53, C63, C83, C93, C13X, C33X, C43X, C93X

Countries:

AL, AT, BE, BG, CH, CY, CZ, DE, DK, EE, ES, FI, FR, GB, GR, HR, HU, IE, IS, IT, LT, LU, LV, MK, MT, NO, NL, PL, PT, RO, SE, SI, SK, TR

Gas groups:

Group	mbar	Group	mbar	Group	mbar
E	20	Esi	20/25	Lw	20
H	20; 25	E(S)	20	Ls	13
EY20	20	Er	20/25	P	37
HY20	20; 25	M	20		


The above gas groups can be combined according to the standard EN437:2021 and national situation of countries.

Note: Suffix "Y20" means that the appliances are suitable for the use of natural gas of the indicated gas group, mixed with hydrogen resulting in a gas mixture containing up to 20% of Hydrogen gas (H2) when the appliance is set for the reference gas G20.

Remarks: -

The validity of this certificate can be verified on request at the following e-mail address: info@kiwacermet.it

This certificate will expire if there have been any changes to the product that may have an impact on compliance with the requirements of the Directive. This certificate will expire if there have been any updates and / or changes to the Technical Standards applicable unless specifically approved by Kiwa Cermet Italia. Any total or partial reproduction of this document in any form, without Kiwa Cermet Italia express authorization, is prohibited.



Number	KIP-07619	Replaces	KIP-15964/E
Issue date	30-05-2024	Contract number	-
Report number	2002311/2	Scope	Art.4 of No.813/2013 (2-8-2013) and 92/42/EEC (21-05-1992)
PIN	0476CT2311	Module	B (Type testing)

EC TYPE-EXAMINATION CERTIFICATE (BED/R813)

Kiwa Cermet Italia, notified body for council Directive 92/42/EC, hereby declares that the central heating condensing boiler, type(s):

VICTRIX OMNIA
VICTRIX OMNIA 25

Manufacturer

IMMERGAS EUROPE S.r.o.
Priemyselna Ulica 4789
SK-05951 Poprad Metejevce, Slovakia

meet the requirements regarding useful efficiencies according to **article 4 of commission regulation (EU) No. 813/2013** and as described in the **Directive 92/42/EEC on efficiency requirements**.

Reference standard:
EN 15502-1:2021+AC:2022
EN 15502-2-1:2022

This certificate is only valid in combination with the appendix to this certificate, where specific information and/or conditions are given.

CERTIFICATE

Kiwa Cermet Italia S.p.A.
Società con socio unico, soggetta
all'attività di direzione e coordinamento
di Kiwa Italia Holding Srl

Via Cadriano, 23
40057 Granarolo dell'Emilia (BO)

Unità locale
Via Treviso 32/34
31020 San Vendemiano (TV)

Tel +39. 0438 411755

Fax +39.0438 22428

E-mail: info@kiwacermet.it

www.kiwa.it

Organismo Notificato n. 0476
Notified Body nr. 0476

Industry Division Manager

Maurizio Lorenzon

Digitally signed by: LORENZON
MAURIZIO

Date: 30/05/2024 15:54:16



PRD N° 0069PRD

Membro degli Accordi di Mutuo Riconoscimento EA, IAF e ILAC
Signatory of EA, IAF and ILAC Mutual Recognition Agreements

Number	KIP-07619	Page	1 of 1
Issue date	30-05-2024	Scope	Art.4 of No.813/2013 (2-8-2013) and 92/42/EEC (21-05-1992)
Report number	2002311/2	Module	B (Type testing)
PIN	0476CT2311		

APPENDIX TO EU TYPE-EXAMINATION CERTIFICATE (BED/R813)

Brand name:
IMMERGAS

Specifications:

Model(s):
VICTRIX OMNIA
VICTRIX OMNIA 25

Condensing boiler:	yes
Range rated:	yes
Low-temperature boiler:	no
B1 boiler:	no
Combination heater:	yes

	Symbol	Value	Unit
Useful heat output			
At rated heat output and high-temperature regime (*)	P ₄	20,2	kW
At 30 % of rated heat output and low-temperature regime (**)	P ₁	6,6	kW
Useful efficiencies (GCV)			
At rated heat output and high-temperature regime (*)	η ₄	87,3	%
At 30 % of rated heat output and low-temperature regime (**)	η ₁	96,2	%
Useful efficiencies (NCV)			
At rated heat output and high-temperature regime (*)	η ₁₀₀	96,9	%
At 30 % of rated heat output and low-temperature regime (**)	η ₃₀	106,8	%

(*) High-temperature regime means 60 °C return temperature at heater inlet and 80 °C feed temperature at heater outlet.

(**) Low temperature means for condensing boilers 30 °C, for low-temperature boilers 37 °C and for other heaters 50 °C return temperature (at heater inlet).

(GCV) Calculated values are based on Gross calorific value (reference conditions:15 °C, 1013,25 mbar)

(NCV) Calculated values are based on Net calorific value (reference conditions:15 °C, 1013,25 mbar)

The validity of this certificate can be verified on request at the following e-mail address: info@kiwacermet.it
This certificate will expire if there have been any changes to the product that may have an impact on compliance with the requirements of the Directive. This certificate will expire if there have been any updates and / or changes to the Technical Standards applicable unless specifically approved by Kiwa Cermet Italia. Any total or partial reproduction of this document in any form, without Kiwa Cermet Italia express authorization, is prohibited.